

CON-56INEC CON-56OUEC				If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.			
Cooling		Y		Average (mandatory)		Y	
Heating		Y		Warmer (if designed)		N	
				Colder (if designed)		N	
Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
Cooling	Pdesignc	5,2	kW	Cooling	SEER	5,6	-
Heating/Average	Pdesignh	5,2	kW	Heating/Average	SCOP/A	3,8	-
Heating/Warmer	Pdesignh	-	kW	Heating/Warmer	SCOP/W	-	-
Heating/Colder	Pdesignh	-	kW	Heating/Colder	SCOP/C	-	-
Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj			
Tj = 35 °C	Pdc	5,2	kW	Tj=35°C	EERd	3,1	-
Tj = 30 °C	Pdc	3,8	kW	Tj=30°C	EERd	4,6	-
Tj = 25 °C	Pdc	2,4	kW	Tj=25°C	EERd	6,7	-
Tj = 20 °C	Pdc	1,8	kW	Tj=20°C	EERd	9,7	-
Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	4,6	kW	Tj=-7°C	COPd	2,5	-
Tj = 2 °C	Pdh	2,7	kW	Tj=2°C	COPd	3,9	-
Tj = 7 °C	Pdh	1,8	kW	Tj=7°C	COPd	4,6	-
Tj = 12 °C	Pdh	1,6	kW	Tj=12°C	COPd	5,7	-
Tj = bivalent temperature	Pdh	4,6	kW	Tj=bivalent temperature	COPd	2,5	-
Tj = operating limit	Pdh	3,8	kW	Tj=operating limit	COPd	2,4	-
Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2 °C	Pdh	x,x	kW	Tj = 2 °C	COPd	x,x	-
Tj = 7 °C	Pdh	x,x	kW	Tj = 7 °C	COPd	x,x	-
Tj = 12 °C	Pdh	x,x	kW	Tj = 12 °C	COPd	x,x	-
Tj = bivalent temperature	Pdh	x,x	kW	Tj = bivalent temperature	COPd	x,x	-
Tj = operating limit	Pdh	x,x	kW	Tj = operating limit	COPd	x,x	-
Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Tj = 2 °C	Pdh	-	kW	Tj = 2 °C	COPd	-	-
Tj = 7 °C	Pdh	-	kW	Tj = 7 °C	COPd	-	-
Tj = 12 °C	Pdh	-	kW	Tj = 12 °C	COPd	-	-
Tj = bivalent temperature	Pdh	-	kW	Tj = bivalent temperature	COPd	-	-
Tj = operating limit	Pdh	-	kW	Tj = operating limit	COPd	-	-
Tj = - 15 °C	Pdh	-	kW	Tj = - 15 °C	COPd	-	-
Bivalent temperature				Operating limit temperature			
Heating/Average	Tbiv	-7	°C	Heating/Average	ToI	-10	°C
Heating/Warmer	Tbiv	x	°C	Heating/Warmer	ToI	x	°C
Heating/Colder	Tbiv	x	°C	Heating/Colder	ToI	x	°C
Cycling interval capacity				Cycling interval efficiency			
For Cooling	Pcycc	kW	kW	For Cooling	EERcyc	x,x	-
For Heating	Pcyh	kW	kW	For Heating	COPcyc	x,x	-
Degradation co-efficient cooling (**)	Cdc	-	-	Degradation co-efficient cooling (**)	Cdh	x,x	-
Electric power input in power modes other than 'active mode'				Annual electricity consumption			
Off Mode	P <sub>OFF</sub>	0.005	kW	Cooling	Q <sub>ce</sub>	325	kWh/a
Standby Mode	P <sub>SB</sub>	0.005	kW	Heating/Average	Q <sub>HE</sub>	1916	kWh/a
Thermostat-Off Mode	P <sub>TO</sub>	0.042/0.020	kW	Heating/Warmer	Q <sub>HE</sub>	-	kWh/a
Crankcase Heater Mode	P <sub>CK</sub>	0	kW	Heating/Colder	Q <sub>HE</sub>	-	kWh/a
Capacity control (indicate one of three options)				Other items			
Fixed	N			Sound power level (indoor/outdoor)	L <sub>WA</sub>	(58/63)	dB(A)
Staged	N			Global warming potential	GWP	1975	kgCO <sub>2</sub> e q.
Variable	Y			Rated air flow (indoor/outdoor)	-	(650/3200)	m <sup>3</sup> /h
Contact details for obtaining more information	TOYOTOMI CO., LTD. 5-17, MOMOZONO-CHO MIZUHO-KU, NAGOYA, 467-0855 JAPAN						
(*)For staged capacity units, two values divided by a slash ('/') will be declared in each box in the section 'Declared capacity of the unit' and 'declared EER/COP' of the unit.							
(**)If default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.							