

MODEL: CTN-335BRM / CTG-335BRM				If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.			
Cooling		Y		Average (mandatory)		Y	
Heating		Y		Warmer (if designed)		Y	
				Colder (if designed)		N	
Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
Cooling	Pdesignc	3.5	kW	Cooling	SEER	8.5	-
Heating/Average	Pdesignh	3.2	kW	Heating/Average	SCOP/A	4.6	-
Heating/Warmer	Pdesignh	3.5	kW	Heating/Warmer	SCOP/W	5.6	-
Heating/Colder	Pdesignh	N/A	kW	Heating/Colder	SCOP/C	N/A	-
Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj			
Tj = 35 °C	Pdc	3.51	kW	Tj = 35 °C	EERd	4.18	-
Tj = 30 °C	Pdc	2.48	kW	Tj = 30 °C	EERd	6.10	-
Tj = 25 °C	Pdc	1.60	kW	Tj = 25 °C	EERd	9.85	-
Tj = 20 °C	Pdc	0.71	kW	Tj = 20 °C	EERd	15.00	-
Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	2.70	kW	Tj = - 7 °C	COPd	3.05	-
Tj = 2 °C	Pdh	1.68	kW	Tj = 2 °C	COPd	4.55	-
Tj = 7 °C	Pdh	1.10	kW	Tj = 7 °C	COPd	5.80	-
Tj = 12 °C	Pdh	0.87	kW	Tj = 12 °C	COPd	7.00	-
Tj = bivalent temperature	Pdh	3.20	kW	Tj = bivalent temperature	COPd	2.50	-
Tj = operating limit	Pdh	3.20	kW	Tj = operating limit	COPd	2.50	-
Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2 °C	Pdh	3.60	kW	Tj = 2 °C	COPd	2.71	-
Tj = 7 °C	Pdh	2.20	kW	Tj = 7 °C	COPd	5.10	-
Tj = 12 °C	Pdh	0.96	kW	Tj = 12 °C	COPd	6.95	-
Tj = bivalent temperature	Pdh	3.60	kW	Tj = bivalent temperature	COPd	2.71	-
Tj = operating limit	Pdh	3.60	kW	Tj = operating limit	COPd	2.71	-
Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	2.70	kW	Tj = - 7 °C	COPd	3.05	-
Tj = 2 °C	Pdh	1.68	kW	Tj = 2 °C	COPd	4.55	-
Tj = 7 °C	Pdh	1.10	kW	Tj = 7 °C	COPd	5.80	-
Tj = 12 °C	Pdh	0.87	kW	Tj = 12 °C	COPd	7.00	-
Tj = bivalent temperature	Pdh	2.39	kW	Tj = bivalent temperature	COPd	1.90	-
Tj = operating limit	Pdh	3.20	kW	Tj = operating limit	COPd	2.50	-
Tj = - 15 °C	Pdh	3.22	kW	Tj = - 15 °C	COPd	2.12	-
Bivalent temperature				Operating limit temperature			
Heating/Average	Tbiv	-10	°C	Heating/Average	Tol	-10	°C
Heating/Warmer	Tbiv	2	°C	Heating/Warmer	Tol	2	°C
Heating/Colder	Tbiv	-10	°C	Heating/Colder	Tol	-22	°C
Cycling interval capacity				Cycling interval efficiency			
For Cooling	Pcycc	x,x	kW	For Cooling	EERcyc	x,x	-
For Heating	Pcyh	x,x	kW	For Heating	COPcyc	x,x	-
Degradation co-efficient cooling (**)	Cdc	0.25	-	Degradation co-efficient cooling (**)	Cdh	0.25	-
Electric power input in power modes other than 'active mode'				Annual electricity consumption			
Off Mode	P <sub>OFF</sub>	0.00070	kW	Cooling	Q <sub>CE</sub>	144	kWh/a
Standby Mode	P <sub>SB</sub>	0.00070	kW	Heating/Average	Q <sub>HE</sub>	974	kWh/a
Thermostat-Off Mode	P <sub>TO</sub>	0.00700/ 0.01300	kW	Heating/Warmer	Q <sub>HE</sub>	875	kWh/a
Crankcase Heater Mode	P <sub>CK</sub>	0	kW	Heating/Colder	Q <sub>HE</sub>	N/A	kWh/a
Capacity control (indicate one of three options)				Other items			
Fixed	N			Sound power level (indoor/outdoor)	L <sub>WA</sub>	60/64	dB(A)
Staged	N			Global warming potential	GWP	675	kgCO <sub>2</sub> e q.
Variable	Y			Rated air flow (indoor/outdoor)	-	720/1950	m <sup>3</sup> /h
Contact details for obtaining more information	TOYOTOMI CO., LTD. 5-17, MOMOZONO-CHO MIZUHO-KU, NAGOYA, 467-0855 JAPAN						
(*) For staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'declared EER/COP' of the unit.							
(**) If default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.							